

Mr S R Chandrakumar
S R Services
153 Lonsdale Road
Enfield
Middlesex
EN2 7NB

C.C Texaco Filling Station

Environmental Health

Harlow Council
Civic Centre
The Water Gardens
Harlow
Essex CM20 1WG
www.harlow.gov.uk

Our Ref: B/12/04091
Your Ref:
Date: 04/05/2022

Texaco Filling Station, Elizabeth Way, Harlow, Essex. CM19 5AR

Dear Mr S R Chandrakumar

As part of our permit compliance inspection programme I wish to confirm my visit on the 29th March 2022 to the above premises.

I would like to take this opportunity to thank you for your assistance during the inspection.

Please find enclosed an inspection report for the above installation.

Please do not hesitate to contact me should you wish to discuss this matter.

Yours Sincerely

Peter Hayden
Senior Environmental Health Officer
Tel: 01279 446103
Peter.hayden@harlow.gov.uk

LA-PPC Inspection Report

General Information

Inspection Type	Compliance
Local Authority	Harlow District Council
Site Name and Address	Texaco Service Station, The Pinnacles, Harlow, Essex. CM19 5AR
Installation Type	Filling Station (Unloading of Petrol into storage tanks at petrol stations)
Permit Reference	EPR/b/1/14 SR Services
Site Representative Seen	Mr Chandrakumar
Regulator/representative	Harlow Council: Peter Hayden
Inspection Date	29 th March 2022
Report Date	30 th March 2022
Duration of Inspection	30
Review of permit conditions undertaken	New permit issued 2014

Recent History

	Comments	Action
Number of justified complaints received	None	None
Process/Installation changes	The Council's Authorized Process public register is now online https://www.harlow.gov.uk/environmental-permits	None

Future Developments

	Comments	Action
Information relating to EPR	Process Guidance Note 1/14(13) issued December 2013	None
Other relevant information	None	None

Risk Assessment

Risk Assessment Score	0
------------------------------	---

Summary of changes	None
---------------------------	------

Summary of Inspection

Satisfactory Installation

Actions Required

Reference to any breach of condition (or not) and other compliance issues as necessary	None
Other relevant information	None

Compliance Checking

Inspection List	✓, ✗ or N/A	Condition/observation details	Action Required
Logbook and Records			
Storage tank summary	✓	1 Diesel 2 Unleaded 3 Supreme Unleaded	None
Incident Log book present? Any incidents of vapour leaks? Any incidents of vapour locks?	✓	Log book available, no reported incidents.	None
Is the certification for the servicing of the Stage I vapour recovery system present on site? <i>Test every 3 years</i>	✓	Carried out 03-08-2022	None
Is the certification for the servicing of the Stage II vapour recovery system present on site? <i>Test every 3 years</i>	N/A		
Is the certification for the servicing of the pressure relief valves (PVRV) present on site? <i>Test every 3 years</i>	✓	Carried out 03-08-2022	None
Is the certification for the servicing of the vapour return lines for vapour integrity? <i>Test every 5 years</i>	✓	Carried out 03-08-2022	None
Are there training details for staff and competence records?	✓	All current staff have undertaken Texaco training program covering permit conditions and vapour recovery. Seen	None

Is there written procedures for the delivery and filling of tanks?	✓	All delivery drivers following Texaco procedures. DCD	None
Is there a copy of the permit on site?	✓	Yes seen	None
Maintenance records/schedule <ul style="list-style-type: none"> • Maintenance inspections • Examination and testing • Inventory Checking • Installation and repair work carried out 	✓	All records held in log book Electrical examination carried out 21/9/21	None
Notifications received by the regulator of accidents, breakdowns or emissions likely to affect the local community during the period under review.	✓	No notification	None
Site inspection			
Are connection points on tank filling pipes and vapour return pipes fitted with secure seals?	✓	Appear satisfactory	None
Are all connection points secured?	✓	All locked	None
Are the fittings for delivery and vapour return pipes different?	✓	Yes	None
Are connections for vapour return and delivery hose clearly locked and labelled? Is there clear notices/signage near the vapour return connection point reading: “ connect vapour return line before off-loading” “the maximum number of tanker compartments which can be discharged”	✓	Yes	none
Condition of manholes	✓	Appear satisfactory	None
General Housekeeping	✓	Satisfactory	None

1 - Compliance Assessment**Scoring for Compliance Assessment**

Scale of Non-Compliance	Possible Score	Score Awarded
(A) Incident leading to justified complaint but no breach of any specific permit condition or of the general/residual BAT condition.	0 points	0
(B) Incident leading to a justified complaint*.	5 points per incident	0
(C) Breach of permit not leading to formal action.	10 points per breach	0
(D) Incident leading to formal caution, Enforcement Notice or prosecution.	15 points per incident	0
(E) Incident leading to a Prohibition Notice or Suspension Notice.	20 points per incident	0
Total (Max. 50):		0

2 - Assessment of Monitoring, Maintenance and Records**Scoring for Assessment of Monitoring, Maintenance and Records**

Criterion	Possible Score			Score Awarded
	Yes	No	N/A	
(A) Are emissions and emissions monitoring recorded as required in the permit?	0	10	0	0
(B) Process operation modified where any problems indicated by monitoring?	0	5	0	0
(C) Has a written maintenance programme for pollution control equipment been provided to the regulator?	0	5	0	0
(D) Is there a log book at the permitted premises incorporating details of all maintenance, examination and testing, inventory checking, installation and repair work carried out?	0	5	0	0
(E) All relevant documents forwarded to the authority by date required?	-5	10	0	0
Total:				0

3 - Assessment of Management, Training and Responsibility**Scoring for Assessment of Management, Training and Responsibility**

Criterion	Possible Score			Score Awarded
	Yes	No	N/A	
(A) Are procedures in place to ensure proper management, supervision and training for process operations, proper use of equipment and effective preventative maintenance on all plant and equipment concerned with the control of emissions to the air?	0	5	0	0
(B) Are all staff with responsibility for operating the installation trained to be aware of their responsibilities under the permit?	0	10	0	0
(C) Does the operator maintain, and make available on request, a statement of training requirements for each operational post?	0	5	0	0
(D) Does the operator keep, and make available, a record of the training received by each person whose actions may have an impact on the environment?	0	5	0	0
(E) Is there a competent trained person who remains near the tanker during unloading? (Delivery drivers may be trained as the competent person.)	0	5	0	0
(F) Is an 'appropriate' environmental management system in place and working effectively?	-5	0	0	0
Total:				0

4 - Determination of Regulatory Effort from Scores

Actual score = 0	Score band = <30	Category = Low
-------------------------	----------------------------	-----------------------